


Certificate of Compliance

Certificate Number 090206-E103582

Report Reference E103582

Issue Date 2006 February 9

Page 1 of 1



Issued to: **Sarel SA**
Rte De Phalsbourg
67260 Sarre-Union, France


This is to certify that representative samples of **Industrial Control Equipment Enclosures**
18100 Inox Series

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 508, Industrial Control Equipment
CAN/CSA C22.2 No. 14-M91, Industrial Control Equipment Certified For Canada

Additional Information: These enclosures are intended for use with open type industrial control panels. Single door having a maximum height of 2000 mm and a width of 800 mm are rated Type 1, 2, 3, 3R, 4, 4X, 5, 12, 12K, and 13. Double door enclosures having a maximum height of 2000 mm and 1000 to 1600 mm wide are rated Type 1, 12, and 12K.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Hilary Frei*
Hilary Frei
Underwriters Laboratories Inc.

Reviewed by: *Daniel Holmquist*
Daniel Holmquist
Underwriters Laboratories Inc.

LISTE DES REFERENCES CONCERNEES PAR LE PRESENT CERTIFICAT
LIST OF REFERENCES CONCERNED BY THIS CERTIFICATE

REFERENCE	DESIGNATION
18141	Spacial inox 300x300x150
18144	Spacial inox 300x200x150
18145	Spacial inox 400x300x150
18148	Spacial inox 400x300x200
18154	Spacial inox 400x400x200
18160	Spacial inox 500x400x200